



Product Service

Attestation of Conformity

No. E8A 18 04 03649 007

Holder of Certificate: **Zhejiang CHINT Instrument & Meter Co., Ltd.**
 Wenzhou Bridge Industrial Zone
 325603 Yueqing
 PEOPLE'S REPUBLIC OF CHINA

Name of Object: **Power meters
 (Three-Phase Smart Meter)**

Model(s): **DTSU666 5(80), DTSU666 1.5(6),
 DSSU666 5(80), DSSU666 1.5(6)**

Description of Object:

Rated voltage:	
DTSU666 5(80):	3*230/400V, 50/60Hz
DTSU666 1.5(6):	3*230/400V, 50/60Hz
DSSU666 5(80):	3*400V, 50/60Hz
DSSU666 1.5(6):	3*400V, 50/60Hz
Rated current:	
DTSU666 5(80):	max. 80A
DTSU666 1.5(6):	max. 6A
DSSU666 5(80):	max. 80A
DSSU666 1.5(6):	max. 6A
Protection class:	II

Tested according to: EN 61326-1:2013
 EN 61326-2-1:2013

This Attestation of Conformity is issued on a voluntary basis according to the Directive 2014/30/EU relating to electromagnetic compatibility. It confirms that the listed apparatus complies with all essential requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: 64713180045701

Date, 2018-04-10 (Tony Liu)



CE After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. That declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.